



TENDER ADDENDUM #1

TO	All Bidders	PROJECT	Thamesford Spray Pad
		PROJECT #	RKLA 16-271 SP Tender # 2018-09 Bidding # 2018-078476-0003
PAGES	1	DATE	May 16, 2018

Bidders:

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Tender Package. This addendum shall be incorporated into the tender package.

Attachments associated with this addendum - o

Questions and Answers (2)

1. Q – Will the water lines need to be bonded by an electrician?
A – **Yes, bonding is required.**
2. Q – What is the process to gain acceptance as an approved alternate?
A – **Proposed alternate product information, including technical specifications, should be submitted to Ron Koudys Landscape Architects for review.**