



TOWNSHIP OF ZORRA

274620 27th Line, PO Box 306 Ingersoll, ON, N5C 3K5
Ph. 519-485-2490 • 1-888-699-3868 • Fax 519-485-2520
Website www.zorra.on.ca • Email admin@zorra.on.ca

TENDER 2018-06 ADDENDUM #1

To: All Bidders
Project: Embro Fire Station Addition
Date: June 26, 2018

Bidders: Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Tender Package. This addendum shall be incorporated into the tender package.


Attachments associated with this addendum - 0

Addendums (5)

1. Q – Which Bay is to be bricked in?
A – C.2.1 (4th bullet) should read “Existing Bay 3”.
2. Q - Is existing lighting to be replaced?
A – All existing lighting to be replaced/ upgraded to LED lighting.
3. Q – Please confirm overhead door size.
A – C.2.1 (3rd bullet) – Door size to be 14’ x 12’ to match the existing door size.
4. Q - Please confirm bay 2 is to remain clear of ancillary rooms.
A – Yes, Bay 2 should remain clear of ancillary rooms.
5. Q – Clarify Station Signage.
A – Station signage to read:

ZORRA FIRE & EMERGENCY SERVICES EMBRO STATION

As per sample below:



Questions and Answers (4)

1. Q - Information on the sanitary lines out of the existing hall.
A – Sanitary exists out on north wall (west corner where fire hall and Town Hall meet) and goes east to the sewer, connecting at Huron Street.
2. Q - Confirm entire garage to be serviced by CO/NO detection and exhaust.
A – Yes.
3. Q - Please confirm overhead doors to operate faster than typical doors.
A – Yes, high speed door opener.
4. Q – Clarify roof line.
A – West end wall (roof line) Gable End to be boxed in with anchor point and ventilation/exhaust fan (to act as hose drying tower).