



## TOWNSHIP OF ZORRA

---

274620 27<sup>th</sup> Line, PO Box 306 Ingersoll, ON, N5C 3K5  
Ph. 519-485-2490 • 1-888-699-3868 • Fax 519-485-2520  
Website [www.zorra.on.ca](http://www.zorra.on.ca) • Email [admin@zorra.on.ca](mailto:admin@zorra.on.ca)

### **TENDER 2018-06 ADDENDUM #2**

To: All Bidders  
Project: Embro Fire Station Addition  
Date: June 28, 2018

Bidders: Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Tender Package. This addendum shall be incorporated into the tender package.

**Attachments associated with this addendum - 0**

#### **Questions and Answers (4)**

1. Q – Flooring in training room to be new (similar) VCT tile OR rubber laminate. Please confirm vinyl plank flooring is acceptable as rubber laminate.  
A – No. Commercial grade flooring to be used.
  2. Q – A shower is called for in the barrier free washroom, this will be by code a barrier free shower.  
A – Yes.
  3. Q – will a urinal be required in existing bathroom renovation?  
A – Yes.
  4. Q – There may be issues in relation to by-law compliance for items such as lot setback and parking spaces requires. Can we assume the municipality will deal with such items through minor variances and design to the specifications indicated?  
A – Yes. A Minor Variance has been approved for the site.
- 
-